



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no.	: NL13-400-1002-048-11	Revision no.: 5
Description of the product	: Lift Control Unit for electric lifts with monitoring circuit for safety chain and door bridging circuit, also applied for monitoring, detection and activation of unintended car movement protection (UCMP)	
Trademark	: Arkel	
Type no.	: ARCODE	
Name and address of the manufacturer	: ARKEL Elektrik Elektronik San. ve Tic. As. Eyup Sultan Mah. Sah Cihan Cad. No:69 34885 Sancaktepe, Istanbul, Turkey	
Name and address of the certificate holder	: ARKEL Elektrik Elektronik San. ve Tic. As. Eyup Sultan Mah. Sah Cihan Cad. No:69 34885 Sancaktepe, Istanbul, Turkey	
Certificate issued on the following requirements	: Lifts Directive 2014/33/EU	
Certificate based on the following standard	: EN 81-20:2020 and EN 81-50:2020 (EN 81-1:1998+A3:2009)	
Test laboratory	: None	
Date and number of the laboratory report	: None	
Date of EU-type examination	: March – September 2013, Rev.1; November 7, 2014, Rev.2; August 2015, Rev.3; April 2016, Rev. 4; August 2018, Rev.5; April 19, 2021	
Additional document with this certificate	: Report belonging to the EU-type examination certificate no.: NL13-400-1002-048-11 rev.5	
Additional remarks	: Key parameters for detecting UCM Detection distance (variable) : ML magnets switching point Max. response time DBR board : 10 ms Speed and distance travelled : to be calculated	
Conclusion	: The safety component meets the requirements of the Lifts Directive 2014/33/EU taking into account any additional remarks mentioned above.	

Amsterdam

Date : 19-04-2021
Valid until : 19-04-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by